

NAVY

Tele: 2150755

Chief Engineer Navy Bombay
26, Assaye Building
Colaba, Bombay-400 005

40010/3/74/1E4

23 May '96

✓
M/s Polaris Cables & Wires Pvt Ltd.,
43, Parul, Janaki Kutir
Juhu Church, Juhu Tara Rd.,
Bombay-400 049

APPROVAL OF PRODUCT OF M/S POLARIS
CABLES & WIRES PVT LTD., BOMBAY

Dear Sir,

1. Reference your letter No.PCWPL: 073/95-96 dated
05 Feb 96.


2. The following products manufactured by your firm
and bearing ISI Mark have been approved on trial basis
subject to satisfactory performance and renewal of IS
certificate when due. If at any stage the performance is
found unsatisfactory and beyond laid down specifications,
this approval shall be cancelled. :-

(a) Heavy duty power cables and control - As per
cables - PVC insulated PVC sheathed IS-1554
armoured/unarmoured suitable for working
voltage upto and including 1100 V with
copper and aluminum conductors.

(b) House hold wires and Flexible PVC - As per
insulated, PVC, Sheathed (Unarmoured) IS-694
suitable for 650/1100 V with copper and
Aluminum conductor.

(c) Submersible cables winding wires. - As per
IS-8783

Yours faithfully,



(RK Kautas)
Lt Col
SO 1 E/M
for Chief Engineer