



INSPECTION VISIT SLIP
(THIS IS NOT A CLEARANCE LETTER)

Date: 28/8/2004
No. QSS/RPN/DIR/2004

1. QSS Ref. No. : ENGG/DIV/MB/34/04
2. Name of the Company : M/s Polaris Cable & Wire Pvt Ltd.
3. Name of the Person Contacted : Mr. Ashok Bhansali / Mr. Sushil Bagat
4. Material offered (Packed / Unpacked)
No. of Packages Offered : 2x10 50mm L.T.P.V.C cable 25 Drum
Length: 24558 in MTRs.

5. Purchase Order / LC No.
Proforma Invoice / Packing list No. : PO/BEPC/PO7000048 Rev no dt 1/3/04

6. Place & Date of attendance : Katgiran Pulghar, on 28/8/2004

7. Time in 10:00 hrs : Time out 13:00 hrs

8. REMARKS :
- ① Drum identification nos with cable length as per Packing list found correct.
 - ② Out of 25 drums 2 drums selected for sample inspection. @ 040824/61 ③ 040824/74
 - ④ H.V. C.R. Muggar Test completed on sample.
 - ⑤ I.R., Hot water Test, Tensile Test, Elongation Test completed. witness report attached.
 - ⑥ Double sticker on sample drums only. A.S.S sticker Pasted on outer side of cable drums.
 - ⑦ Documents received. P.O. Internal Test Report. Calibration Certificate etc.

9. Stamped / Stenciled (For identification purpose only) :


10. Please refer REMARKS, if any (Sr. No. 8).

11. This inspection is valid for 30 days from the date of inspection.

Company Representative


Sushil Bagat
(Name & Signature With Seal)

for Quality Services & Solutions (QSS)



(Inspector's Name & Signature)

R. P. NATU